

IDWGP February Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	7.17	225.2	0.30	174,219	189,377	0.80	561.8	0.7	99.9
T2	Z-50	6.86	192.5	0.26	135,859	175,889	0.74	553.5	37.8	94.4
T3	Z-50	6.39	199.5	0.27	141,318	164,135	0.82	555.8	11.7	98.3
Avg.		6.81	205.7	0.27	150,465	176,467	0.78	557.0	16.7	97.5
Tot.					451,396	529,402		1,671.2	50.2	
* IDWGP Monthly Station Power Consumption										
February 1 st , 2010 thru				February 28, 2010			34 918			
IDWGP Monthly Net Generation										
February 1 st , 2010 thru				February 28, 2010			416 478			
IDWGP YTD Net Production										
January 1 st , 2010 thru				February 28, 2010			957 061			
** IDWGP Monthly Power Consumption from Grid										
February 1 st , 2010 thru				February 28, 2010			1 692			
** IDWGP YTD Power Consumption from Grid										
January 1 st , 2010 thru				February 28, 2010			3 901			

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.