

IDWGP March Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	9.33	291.5	0.39	234,788	293,187	0.74	683.7	0.5	99.9
T2	Z-50	8.90	239.2	0.32	191,157	274,966	0.65	668.2	15.2	98.0
T3	Z-50	7.90	217.2	0.29	170,116	219,332	0.74	506.3	198.7	73.3
Avg.		8.71	249.3	0.33	198,687	262,495	0.71	619.3	71.5	90.4
Tot.					596,061	787,485		1,858.2	214.3	
* IDWGP Monthly Station Power Consumption										
March 1 st , 2009 thru				March 31 st , 2009			47 711			
IDWGP Monthly Net Generation										
March 1 st , 2009 thru				March 31 st , 2009			548 350			
IDWGP YTD Net Production										
January 1 st , 2009 thru				March 31 st , 2009			1 640 800			
** IDWGP Monthly Power Consumption from Grid										
March 1 st , 2009 thru				March 31 st , 2009			960			
** IDWGP YTD Power Consumption from Grid										
January 1 st , 2009 thru				March 31 st , 2009			4 360			

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.