

IDWGP March Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	8.46	289.4	0.39	242,508	280,213	0.77	655.8	1.5	99.8
T2	Z-50	7.70	219.5	0.29	172,666	244,075	0.70	617.3	67.2	91.0
T3	Z-50	7.29	245.0	0.33	195,771	216,760	0.84	662.0	1.3	99.8
Avg.		7.82	251.3	0.34	203,648	243,683	0.77	645.0	23.3	96.9
Tot.					610,945	731,048		1,935.2	70.2	
* IDWGP Monthly Station Power Consumption										
March 1 st , 2010 thru				March 31 st , 2010				60 173		
IDWGP Monthly Net Generation										
March 1 st , 2010 thru				March 31 st , 2010				550 772		
IDWGP YTD Net Production										
January 1 st , 2010 thru				March 31 st , 2010				1 507 833		
** IDWGP Monthly Power Consumption from Grid										
March 1 st , 2010 thru				March 31 st , 2010				1 221		
** IDWGP YTD Power Consumption from Grid										
January 1 st , 2010 thru				March 31 st , 2010				5 122		

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.