

## IDWGP September Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	7.70	218.9	0.29	137,771	191,715	0.72	531.0	98.7	86.3
T2	Z-50	7.40	178.5	0.24	112,243	176,997	0.63	487.7	105.2	85.4
T3	Z-50	6.83	219.9	0.29	138,139	153,732	0.90	538.5	100.2	86.1
Avg.		7.31	205.8	0.27	129,384	174,148	0.75	519.07	101.3	85.9
Tot.					388,152	522,445		1,557.2	304.5	
<b>* IDWGP Monthly Station Power Consumption</b>										
September 1st, 2010 thru				September 30th, 2010				***7 500		
<b>IDWGP Monthly Net Generation</b>										
September 1st, 2010 thru				September 30th, 2010				421 207		
<b>IDWGP YTD Net Production</b>										
January 1st, 2010 thru				September 30th, 2010				3 798 302		
<b>** IDWGP Monthly Power Consumption from Grid</b>										
September 1st, 2010 thru				September 30th, 2010				1 523		
<b>** IDWGP YTD Power Consumption from Grid</b>										
January 1st, 2010 thru				September 30th, 2010				16 426		

\* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

\*\* Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.

\*\*\*Estimated amount due to communications failure between September 16 and 22.