

## IDWGP September Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	6.34	132.8	0.18	103,436	146,231	0.65	518.2	59.5	91.7
T2	Z-50	5.42	120.5	0.16	94,735	113,492	0.76	529.5	73.5	89.8
T3	Z-50	5.04	124.0	0.17	101,211	103,461	0.86	572.3	4.0	99.4
Avg.		5.60	125.7	0.17	99,794	121,061	0.76	540.0	45.7	93.7
Tot.					299,382	363,183		1,620.0	137.0	
* IDWGP Monthly Station Power Consumption										
September 1 <sup>st</sup> , 2011 thru				September 30th, 2011			28 812			
IDWGP Monthly Net Generation										
September 1 <sup>st</sup> , 2011 thru				September 30th, 2011			270 570			
IDWGP YTD Net Production										
January 1 <sup>st</sup> , 2011 thru				September 30th, 2011			3 513 909			
** IDWGP Monthly Power Consumption from Grid										
September 1 <sup>st</sup> , 2011 thru				September 30th, 2011			2 390			
** IDWGP YTD Power Consumption from Grid										
January 1 <sup>st</sup> , 2011 thru				September 30th, 2011			14 984			

\* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

\*\* Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.