

## IDWGP August Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	6.19	121.1	0.16	89,884	130,866	0.69	617.0	19.3	97.4
T2	Z-50	6.05	120.8	0.16	89,668	128,410	0.70	627.8	3.8	99.5
T3	Z-50	5.75	127.5	0.17	94,639	108,650	0.87	633.5	4.3	99.4
Avg.		6.00	123.2	0.16	91,397	122,642	0.75	626.2	9.2	98.8
Tot.					274,192	367,926		1878.3	27.5	
* IDWGP Monthly Station Power Consumption										
August 1st,2004 thru				August 31st,2004				6 792		
IDWGP Monthly Net Generation										
August 1st,2004 thru				August 31st,2004				267 400		
IDWGP YTD Net Production										
January 1st,2004 thru				August 31st,2004				3 466 400		
** IDWGP Monthly Power Consumption from Grid										
August 1st,2004 thru				August 31st,2004				1 400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2004 thru				August 31st,2004				12 600		

\* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

\*\* Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.