

## IDWGP August Production

Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	6.29	141.0	0.19	104,234	147,556	0.71	498.0	12.8	98.3
T2	Z-50	5.83	135.6	0.18	100,190	128,356	0.78	493.8	14.7	98.0
T3	Z-50	5.30	121.0	0.16	89,381	111,700	0.80	470.0	49.7	93.3
Avg.		5.81	132.6	0.18	97,935	129,204	0.76	487.3	25.7	96.5
Tot.					293,804	387,612		1,461.8	77.2	

### YTD Production

January 1st, 1999 thru	August 31st, 1999	4 316 200 kWHrs
------------------------	-------------------	-----------------