

## IDWGP December Production

Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	8.2	294.2	0.39	209,802	246,465	0.85	598.2	41.7	94.2
T2	Z-50	8.11	281.1	0.37	202,391	246,032	0.82	602.5	13.7	98.1
T3	Z-50	8.02	286.3	0.38	205,796	236,283	0.87	619.2	9.0	98.8
Avg.		8.11	287.2	0.38	205,997	242,927	0.85	606.7	21.5	97.0
Tot.					617,990	728,780		1,819.8	64.3	

### YTD Production

January 1st, 1999 thru	December 30th, 1999	5 965 730 kWHrs
------------------------	---------------------	-----------------