

IDWGP February Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	8.84	220.4	0.29	153,424	273,246	0.56	662.0	0.0	100.0
T2	Z-50	8.72	333.7	0.44	232,260	269,006	0.86	660.8	0.0	100.0
T3	Z-50	8.28	327.7	0.44	228,089	239,044	0.95	662.5	0.0	100.0
Avg.		8.61	294.0	0.39	204,591	260,432	0.79	661.8	0.0	100.0
Tot.					613,773	781,296		1,985.3	0.0	
* IDWGP Monthly Station Power Consumption										
February 1st,2004 thru				February 29th,2004				11,773		
IDWGP Monthly Net Generation										
February 1st,2004 thru				February 29th,2004				602,000		
IDWGP YTD Net Production										
January 1st,2004 thru				February 29th,2004				1,083,600		
** IDWGP Monthly Power Consumption from Grid										
February 1st,2004 thru				February 29th,2004				1,400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2004 thru				February 29th,2004				2,800		

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.