

## IDWGP February Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	8.53	284.8	0.38	191,386	238,573	0.80	628.0	0.5	99.9
T2	Z-50	8.35	248.6	0.33	167,046	227,072	0.74	578.2	53.0	92.1
T3	Z-50	7.75	246.4	0.33	163,720	194,594	0.84	578.0	52.0	92.3
Avg.		8.21	259.9	0.35	174,051	220,080	0.79	594.7	35.2	94.8
Tot.					522,153	660,240		1,784.2	105.5	
* IDWGP Monthly Station Power Consumption										
February 1st,2006 thru				February 28th,2006				2 000		
IDWGP Monthly Net Generation										
February 1st,2006 thru				February 28th,2006				523 600		
IDWGP YTD Net Production										
January 1st,2006 thru				December 31st,2006				1 297 800		
** IDWGP Monthly Power Consumption from Grid										
February 1st,2006 thru				February 28th,2006				1 400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2006 thru				December 31st,2006				2 800		

\* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity. This month is an estimated amount due to communications issues.

\*\* Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.