

IDWGP February Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	8.67	284.1	0.38	190,925	242,491	0.79	601.5	16.2	97.6
T2	Z-50	8.22	184.2	0.25	123,354	219,538	0.56	436.2	175.3	73.9
T3	Z-50	8.01	265.7	0.35	178,525	210,118	0.85	532.3	90.5	86.5
Avg.		8.30	244.6	0.33	164,268	224,049	0.73	523.3	94.0	86.0
Tot.					492,804	672,147		1,570.0	282.0	
* IDWGP Monthly Station Power Consumption										
February 1st,2007 thru				February 28th,2007			1 404			
IDWGP Monthly Net Generation										
February 1st,2007 thru				February 28th,2007			491 400			
IDWGP YTD Net Production										
January 1st,2007 thru				February 28th,2007			1 251 600			
** IDWGP Monthly Power Consumption from Grid										
February 1st,2007 thru				February 28th,2007			0			
** IDWGP YTD Power Consumption from Grid										
January 1st,2007 thru				February 28th,2007			1 400			

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.