

IDWGP January Production

| IDWGP Gross Production Table | | | | | | | | | | |
|--|--------------|-------------------|--------------------|-------------------|----------------------|-------------------------|-------------|--------------|-------------|-------------|
| Turbine Name | Turbine Type | Average W/S (m/s) | Average Power (kW) | Capacity Factor | Total Energy (kWHrs) | Expected Energy (kWHrs) | Perf. Ratio | Online (Hrs) | N.Rdy (Hrs) | Avlblty (%) |
| T1 | Z-50 | 8.27 | 206.3 | 0.28 | 153,470 | 253,288 | 0.61 | 625.7 | 55.7 | 92.5 |
| T2 | Z-50 | 8.50 | 307.6 | 0.41 | 228,866 | 271,641 | 0.84 | 682.0 | 1.7 | 99.8 |
| T3 | Z-50 | 7.06 | 137.5 | 0.18 | 95,975 | 172,716 | 0.56 | 338.8 | 371.8 | 50.0 |
| Avg. | | 7.94 | 217.1 | 0.29 | 159,437 | 232,548 | 0.67 | 548.8 | 143.0 | 80.8 |
| Tot. | | | | | 478,311 | 697,645 | | 1,646.5 | 429.2 | |
| * IDWGP Monthly Station Power Consumption | | | | | | | | | | |
| January 1st,2004 | | | | January 31st,2004 | | | 3,289 | | | |
| IDWGP Monthly Net Generation | | | | | | | | | | |
| January 1st,2004 thru | | | | January 31st,2004 | | | 481,600 | | | |
| IDWGP YTD Net Production | | | | | | | | | | |
| January 1st,2004 thru | | | | January 31st,2004 | | | 481,600 | | | |
| ** IDWGP Monthly Power Consumption from Grid | | | | | | | | | | |
| January 1st,2004 thru | | | | January 31st,2004 | | | 1,400 | | | |
| ** IDWGP YTD Power Consumption from Grid | | | | | | | | | | |
| January 1st,2004 thru | | | | January 31st,2004 | | | 1,400 | | | |

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.