

## IDWGP January Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	9.48	350.6	0.47	260,882	326,306	0.80	678.2	4.2	99.4
T2	Z-50	9.47	324.5	0.43	241,455	322,327	0.75	666.2	16.2	97.8
T3	Z-50	8.94	345.5	0.46	257,025	292,502	0.88	677.2	6.5	99.1
Avg.		9.30	340.2	0.45	253,121	313,712	0.81	673.8	9.0	98.8
Tot.					759,362	941,136		2,021.5	26.8	
* IDWGP Monthly Station Power Consumption										
January 1st,2006 thru				January 31st,2006				3 500		
IDWGP Monthly Net Generation										
January 1st,2006 thru				January 31st,2006				774 200		
IDWGP YTD Net Production										
January 1st,2006 thru				December 31st,2006				774 200		
** IDWGP Monthly Power Consumption from Grid										
January 1st,2006 thru				January 31st,2006				1 400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2006 thru				December 31st,2006				1 400		

\* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity. This month is an estimated amount due to a communications failure.

\*\* Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.