

## IDWGP July Production

Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	6.91	193.6	0.26	141,481	180,869	0.78	522.0	24.5	96.7
T2	Z-50	6.53	174.9	0.23	127,561	161,924	0.79	491.8	35.7	95.2
T3	Z-50	6.69	187.6	0.25	137,399	169,068	0.81	521.8	26.8	96.4
Avg.		6.71	185.3	0.25	135,480	170,620	0.79	511.8	29.0	96.1
Tot.					406,441	511,861		1,535.7	87.0	

### YTD Production

January 1st, 1999 thru	July 31st, 1999	4 027 800 kWHrs
------------------------	-----------------	-----------------