

IDWGP June Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	6.71	156.1	0.21	112,208	165,561	0.68	552.5	40.8	94.3
T2	Z-50	6.71	172.9	0.23	124,339	171,358	0.73	589.3	3.8	99.5
T3	Z-50	6.31	164.7	0.22	118,266	146,026	0.81	580.2	27.2	96.2
Avg.		6.58	164.6	0.22	118,271	160,982	0.74	574.0	24.0	96.7
Tot.					354,814	482,945		1,722.0	71.8	
* IDWGP Monthly Station Power Consumption										
June 1st,2003				June 30th,2003				4,814		
IDWGP Monthly Net Generation										
June 1st,2003 thru				June 30th,2003				350,000		
IDWGP YTD Net Production										
January 1st,2003 thru				June 30th,2003				3,456,600		
** IDWGP Monthly Power Consumption from Grid										
June 1st,2003 thru				June 30th,2003				1,400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2003 thru				June 30th,2003				8,400		

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.