

## IDWGP June Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	6.19	104.0	0.14	22,125	39,170	0.56	170.0	516.7	28.2
T2	Z-50	6.45	120.2	0.16	84,687	139,786	0.61	469.8	170.5	76.3
T3	Z-50	6.43	172.0	0.23	121,423	139,939	0.87	610.0	20.0	97.2
Avg.		6.36	132.1	0.18	76,078	106,298	0.68	416.7	235.7	67.3
Tot.					228,235	318,895		1,249.8	707.2	
* IDWGP Monthly Station Power Consumption										
June 1st,2004 thru				June 30th,2004				7,035		
IDWGP Monthly Net Generation										
June 1st,2004 thru				June 30th,2004				221,200		
IDWGP YTD Net Production										
January 1st,2004 thru				June 30th,2004				3,007,200		
** IDWGP Monthly Power Consumption from Grid										
June 1st,2004 thru				June 30th,2004				2,800		
** IDWGP YTD Power Consumption from Grid										
January 1st,2004 thru				June 30th,2004				8,400		

\* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

\*\* Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.