

IDWGP June Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	7.58	204.0	0.27	146,873	211,065	0.70	590.3	4.5	99.4
T2	Z-50	7.32	189.3	0.25	136,317	198,490	0.69	565.0	55.2	92.3
T3	Z-50	7.27	216.8	0.29	155,907	195,894	0.80	610.7	18.7	97.4
Avg.		7.39	203.4	0.27	146,366	201,816	0.73	588.7	26.2	96.4
Tot.					439,097	605,449		1766.0	78.3	
* IDWGP Monthly Station Power Consumption										
June 1st,2005 thru				June 30th,2005				9 297		
IDWGP Monthly Net Generation										
June 1st,2005 thru				June 30th,2005				429 800		
IDWGP YTD Net Production										
January 1st,2005 thru				June 30th,2005				3 358 600		
** IDWGP Monthly Power Consumption from Grid										
June 1st,2005 thru				June 30th,2005				1 400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2005 thru				June 30th,2005				8 400		

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.