

IDWGP March Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	9.14	193.3	0.26	141,420	276,270	0.51	668.0	17.7	97.6
T2	Z-50	8.99	332.6	0.44	243,331	276,374	0.88	665.2	18.3	97.5
T3	Z-50	8.47	318.0	0.42	220,620	237,487	0.93	625.8	64.3	91.4
Avg.		8.87	281.3	0.38	201,790	263,377	0.77	653.0	33.5	95.5
Tot.					605,371	790,131		1959.0	100.3	
* IDWGP Monthly Station Power Consumption										
March 1st,2004 thru				March 31st,2004			4,771			
IDWGP Monthly Net Generation										
March 1st,2004 thru				March 31st,2004			600,600			
IDWGP YTD Net Production										
January 1st,2004 thru				March 31st,2004			1,684,200			
** IDWGP Monthly Power Consumption from Grid										
March 1st,2004 thru				March 31st,2004			1,400			
** IDWGP YTD Power Consumption from Grid										
January 1st,2004 thru				March 31st,2004			4,200			

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.