

IDWGP March Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	8.58	278.8	0.37	207,428	257,444	0.81	624.3	46.3	93.8
T2	Z-50	8.45	286.1	0.38	212,854	252,359	0.84	682.3	2.5	99.7
T3	Z-50	8.19	279.4	0.37	207,812	237,930	0.87	668.8	17.3	97.7
Avg.		8.41	281.4	0.38	209,365	249,245	0.84	658.5	22.0	97.0
Tot.					628,094	747,734		1,975.5	66.2	
* IDWGP Monthly Station Power Consumption										
March 1st,2005 thru				March 31st,2005				6 494		
IDWGP Monthly Net Generation										
March 1st,2005 thru				March 31st,2005				621 600		
IDWGP YTD Net Production										
January 1st,2005 thru				March 31st,2005				1 659 000		
** IDWGP Monthly Power Consumption from Grid										
March 1st,2005 thru				March 31st,2005				1 400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2005 thru				March 31st,2005				4200		

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.