

## IDWGP March Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	9.07	314.8	0.42	234,236	292,347	0.80	690.3	1.8	99.8
T2	Z-50	9.19	303.1	0.40	225,479	297,919	0.76	691.5	4.0	99.5
T3	Z-50	8.43	276.6	0.37	205,774	257,126	0.80	649.8	44.0	94.1
Avg.		8.90	298.2	0.40	221,830	282,464	0.79	677.2	16.7	97.8
Tot.					665,489	847,392		2,031.7	49.8	
* IDWGP Monthly Station Power Consumption										
March 1st,2006 thru				March 31st,2006				1 000		
IDWGP Monthly Net Generation										
March 1st,2006 thru				March 31st,2006				666 400		
IDWGP YTD Net Production										
January 1st,2006 thru				December 31st,2006				1 964 200		
** IDWGP Monthly Power Consumption from Grid										
March 1st,2006 thru				March 31st,2006				1 400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2006 thru				December 31st,2006				4 200		

\* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity. This month is an estimated amount due to communications issues.

\*\* Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.