

## IDWGP March Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	9.06	330.0	0.44	245,116	303,341	0.81	678.7	5.0	99.3
T2	Z-50	8.80	195.1	0.39	219,318	289,016	0.76	630.8	54.3	92.7
T3	Z-50	8.28	216.2	0.29	160,614	258,084	0.62	586.8	118.3	84.1
Avg.		8.71	280.4	0.37	208,350	283,480	0.73	632.2	59.2	92.0
Tot.					625,049	850,441		1,896.3	177.7	
* IDWGP Monthly Station Power Consumption										
March 1st,2007 thru				March 31st,2007			3 449			
IDWGP Monthly Net Generation										
March 1st,2007 thru				March 31st,2007			621 600			
IDWGP YTD Net Production										
January 1st,2007 thru				March 31st,2007			1 873 200			
** IDWGP Monthly Power Consumption from Grid										
March 1st,2007 thru				March 31st,2007			1 400			
** IDWGP YTD Power Consumption from Grid										
January 1st,2007 thru				March 31st,2007			2 800			

\* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

\*\* Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.