

## IDWGP March Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	7.52	237.3	0.32	176,266	219,938	0.80	614.7	3.3	99.6
T2	Z-50	7.09	198.3	0.26	147,278	197,905	0.74	543.0	86.3	88.4
T3	Z-50	6.56	155.3	0.21	115,266	177,355	0.65	519.5	117.7	84.2
Avg.		7.06	197.0	0.26	146,270	198,400	0.73	559.0	69.2	90.7
Tot.					438,810	595,199		1,677.2	207.3	
* IDWGP Monthly Station Power Consumption										
March 1st, 2008 thru				March 31st, 2008			* -11 990			
IDWGP Monthly Net Generation										
March 1st, 2008 thru				March 31st, 2008			450 800			
IDWGP YTD Net Production										
January 1st, 2008 thru				March 31st, 2008			1 492 400			
** IDWGP Monthly Power Consumption from Grid										
March 1st, 2008 thru				March 31st, 2008			2 800			
** IDWGP YTD Power Consumption from Grid										
January 1st, 2008 thru				March 31st, 2008			5 600			

\* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity. This number is off due to loss of communication with the wind farm over a short period of time.

\*\* Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.