

## IDWGP May Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	9.28	310.4	0.41	230,890	305,409	0.76	711.8	0.7	99.9
T2	Z-50	8.94	292.8	0.39	217,855	283,477	0.77	689.5	25.0	96.6
T3	Z-50	8.87	312.5	0.42	232,488	278,368	0.84	712.0	1.3	99.8
Avg.		9.03	305.2	0.41	227,077	289,085	0.79	704.5	9.0	98.8
Tot.					681,232	867,254		2,113.3	27.0	
* IDWGP Monthly Station Power Consumption										
May 1st,2006 thru				May 31st,2006			568			
IDWGP Monthly Net Generation										
May 1st,2006 thru				May 31st,2006			681 800			
IDWGP YTD Net Production										
January 1st,2006 thru				December 31st,2006			3 357 200			
** IDWGP Monthly Power Consumption from Grid										
May 1st,2006 thru				May 31st,2006			2 800			
** IDWGP YTD Power Consumption from Grid										
January 1st,2006 thru				December 31st,2006			8 400			

\* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

\*\* Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.