

IDWGP November Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	7.82	242.6	0.32	174,636	221,609	0.79	659.3	0.8	99.9
T2	Z-50	7.57	226.5	0.30	163,047	210,569	0.77	660.7	1.3	99.8
T3	Z-50	7.17	221.8	0.30	157,206	179,955	0.87	635.0	32.8	95.4
Avg.		7.52	230.3	0.31	164,963	204,044	0.81	651.7	11.7	98.4
Tot.					494,890	612,132		1955.0	35.0	
* IDWGP Monthly Station Power Consumption										
November 1st,2004 thru				November 30th,2004				6 290		
IDWGP Monthly Net Generation										
November 1st,2004 thru				November 30th,2004				488 600		
IDWGP YTD Net Production										
January 1st,2004 thru				November 30th,2004				4 918 200		
** IDWGP Monthly Power Consumption from Grid										
November 1st,2004 thru				November 30th,2004				1 400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2004 thru				November 30th,2004				16 800		

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.