

## IDWGP October Production

Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	7.32	188.6	0.25	135,809	192,788	0.70	573.2	10.2	98.6
T2	Z-50	6.97	185.2	0.25	133,279	173,434	0.77	574.5	11.5	98.4
T3	Z-50	6.85	176.6	0.24	127,130	166,787	0.76	553.3	48.2	93.3
Avg.		7.05	183.5	0.24	132,073	177,669	0.75	567.0	23.3	96.8
Tot.					396,219	533,008		1,701.0	69.8	

### YTD Production

January 1st, 1999 thru	September 30th, 1999	4 706 800 kWHrs
------------------------	----------------------	-----------------