

IDWGP September Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	5.70	1.4	0.00	1,025	93,316	0.01	7.5	396.0	45.0
T2	Z-50	7.58	215.8	0.29	155,162	210,610	0.74	634.2	14.7	98.0
T3	Z-50	7.27	210.4	0.28	151,340	189,139	0.80	636.3	17.7	97.5
Avg.		6.85	142.5	0.19	102,509	164,355	0.52	426.0	142.8	80.2
Tot.					307,527	493,065		1,278.0	428.3	
* IDWGP Monthly Station Power Consumption										
September 1st,2003				September 30th,2003				6,527		
IDWGP Monthly Net Generation										
September 1st,2003 thru				September 30th,2003				301,000		
IDWGP YTD Net Production										
January 1st,2003 thru				September 30th,2003				4,226,600		
** IDWGP Monthly Power Consumption from Grid										
September 1st,2003 thru				September 30th,2003				1,400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2003 thru				September 30th,2003				15,400		

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.