

IDWGP September Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWHrs)	Expected Energy (kWHrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	7.25	140.1	0.19	65,609	117,942	0.56	378.5	290.0	59.7
T2	Z-50	7.29	197.4	0.26	130,304	175,022	0.74	580.7	76.5	89.4
T3	Z-50	7.28	194.9	0.26	128,756	170,567	0.75	585.2	87.2	87.9
Avg.		7.27	177.5	0.24	108,223	154,510	0.69	514.8	151.2	79.0
Tot.					324,669	463,531		1,544.3	453.7	
* IDWGP Monthly Station Power Consumption										
September 1st,2005 thru				September 30th,2005				*** 5 000		
IDWGP Monthly Net Generation										
September 1st,2005 thru				September 30th,2005				345 800		
IDWGP YTD Net Production										
January 1st,2005 thru				September 30th,2005				4 214 000		
** IDWGP Monthly Power Consumption from Grid										
September 1st,2005 thru				September 30th,2005				1 400		
** IDWGP YTD Power Consumption from Grid										
January 1st,2005 thru				September 30th,2005				14 000		

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.

*** Estimated amount due to data loss.