

IDWGP September Production

IDWGP Gross Production Table										
Turbine Name	Turbine Type	Average W/S (m/s)	Average Power (kW)	Capacity Factor	Total Energy (kWhrs)	Expected Energy (kWhrs)	Perf. Ratio	Online (Hrs)	N.Rdy (Hrs)	Avlblty (%)
T1	Z-50	7.98	215.1	0.29	154,478	227,014	0.68	644.3	12.3	98.3
T2	Z-50	7.49	184.3	0.25	118,841	179,430	0.66	557.0	106.8	85.2
T3	Z-50	6.30	56.6	0.08	40,282	122,595	0.33	256.5	429.8	40.3
Avg.		7.26	152.0	0.20	104,534	176,346	0.56	486.0	183.0	74.6
Tot.					313,601	529,039		1,457.8	549.0	
* IDWGP Monthly Station Power Consumption										
September 1st,2007 thru				September 30th,2007				1 399		
IDWGP Monthly Net Generation										
September 1st,2007 thru				September 30th,2007				315 000		
IDWGP YTD Net Production										
January 1st,2007 thru				September 30th,2007				3 672 200		
** IDWGP Monthly Power Consumption from Grid										
September 1st,2007 thru				September 30th,2007				2 800		
** IDWGP YTD Power Consumption from Grid										
January 1st,2007 thru				September 30th,2007				12 600		

* Power consumed by the Wind Farm when the Turbines are on-line and producing electricity.

** Power consumed by the Wind Farm when the Turbines are off-line. This power is feed in to the Turbines from the Grid.